

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175–2474 T (786) 315–2590 F (786) 315–2599 www.miamidade.gov/pera

DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY AFFAIRS (PERA) BOARD AND CODE ADMINISTRATION DIVISION NOTICE OF ACCEPTANCE (NOA)

GAF Materials Corporation 1361 Alps Road Wayne, NJ 07470

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami–Dade County PERA – Product Control Section to be used in Miami–Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: EnergyGuard[™] RH Polyiso Insulation

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, and following statement: "Miami–Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/ or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami–Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge L. Acebo.

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0913.09 Expiration Date: 01/14/15 Approval Date: 01/12/12 Page 1 of 3

ROOFING COMPONENT APPROVAL

<u>Category:</u> Roofing

Sub-Category: Roof Insulation **Materials:** Polyisocyanurate

TYPICAL PHYSICAL PROPERTIES:

Property	<u>Test</u>	Typical Results	
Density	ASTM D 1622	2.0 lbs./ft^3	
		20 psi	
Compressive Strength	ASTM D 1621	24 PSI	
Water Absorption	ASTM C 209	Less than 1% by volume	
Moisture Vapor Transmission	ASTM E 96	Less than one (1) perm	
Service Temperature		-100° F +250° F Max	X
Surface Burning Characteristics	ASTM E 84	Flamespread:	50
(4" Foam Core Max.)		Smoke Developed:	450

Note: The physical properties listed above are presented as typical average values as determined by accepted ASTM test methods and are subject to normal manufacturing variation.

Numerical ratings as determined by ASTM Test Method E 84 are not intended to reflect hazards presented by this or any other material under actual fire conditions.

MANUFACTURING LOCATION:

1. Lake City, FL.

EVIDENCE SUBMITTED:

Test Agency/Identifier	<u>Name</u>	Report	Date
Exterior Research & Design, L.L.C.	Physical Properties	03190.05.04-1	5/24/2004
Factory Mutual Approvals	Class 4450	3009425 3019743 3021539	6/13/2003 6/15/2004 4/27/2005
Factory Mutual Approvals	ASTM-E84	3018331	8/30/2004
Factory Mutual Approvals	ASTM-D1929	3021560	8/31/2004
Factory Mutual Approvals	Fire Classification	3016355	9/15/2004
Underwriters Laboratories	Fire Classification	R 18846	4/15/2003
Underwriters Laboratories	Fire Classification	R 18846	4/16/2003

NOA No.: 11-0913.09 Expiration Date: 01/14/15 Approval Date: 01/12/12 Page 2 of 3



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

Trade name: EnergyGuard[™] RH Polyiso Insulation and EnergyGuard[™] RH Tapered

Polyiso Insulation

Thickness: 0.5" - 4.0" (12.5-102 mm)

Board Size(s) 4' x 4' (1.2 x 1.2 m) and 4' x 8' (1.2 x 2.4 m)

Core: Polyisocyanurate foam Facers: Fiber reinforced facers

Decks: Concrete, Cementitious Wood Fiber, Steel, Wood, Lightweight Concrete,

Gypsum

Special Application: Tapered or flat boards. Multilayer systems to a maximum thickness of 12 inches.

See specific Roof Assembly NOA, and RAS 117 for specific system approvals.

COMMENTS AND LIMITATIONS:

1. Roof assemblies are approved under specific roof cover's Product Control Notice of Acceptance.

- 2. GAF Materials Corporation products may be used with any approved roof covering listing a specific GAF Materials Corporation product as a component part of a roof assembly Notice of Acceptance. If a GAF Materials Corporation product is not listed, a request may be made to the authority having jurisdiction or the Miami Dade Building Code Compliance Office for approval provided that appropriate documentation is provided.
- 3. Fire classification is not a part of this Notice of Acceptance
- 4. All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.





